

# SAFE DRINKING WATER & SANITARY CONDITION CERTIFICATE

File No: 329Date: 29/08/2024It is certified that an inspection team headed by Brijharbato Yadav(Name of Officers) Designation: chemist, District Level water Testing  
Siwan-----fromName of Department / Office Public Health Engineering Department.

inspected the school viz. **MAHAVIRI SARASWATI VIDYA MANDIR at PANCHMANDIRA, BARHAN GOPAL, SIWAN** on 27.08.2024 (date of inspection) and found that **MAHAVIRI SARASWATI VIDYA MANDIR at PANCHMANDIRA, BARHAN GOPAL, SIWAN** (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U.T. Govt.

The above is valid for a period of 1 yearsSignature with Seal: [Signature] 29/08/24Name: Kishor KumarDesignation: Assistant EngineerName & Address of Department / Office: Assistant EngineerP.H. Sub-Division Siwan

(Assistant Engineer &amp; above officer of concerned Govt. Development only)

To,  
**MAHAVIRI SARASWATI VIDYA MANDIR**  
**PANCHMANDIRA, BARHAN GOPAL, SIWAN**

[Signature]

PRINCIPAL  
MAHAVIRI SARASWATI VIDYA MANDIR  
Panchmandira, Barhan Gopal, Siwan-841227  
Affiliation No. 330800, School No. 65797



सचिव  
महोदय महोदय  
पंचमंदिरा बरहान गोपाल, सिवान

The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



बिहार सरकार

**District Level Water Testing Laboratory:- Siwan**

Address- Kachahari Campus Pani Tanki Siwan-841226 (Bihar)

**TEST REPORT**

Name & Address of the Customer :- Mahaviri Saraswati Vidya Mandir, Panchmandira, Barhan Gopal, Siwan.	Date:	28.08.2024
	Sample No.	-
	Sample Description	Drinking Water
	Sampling Plan & Method	IS3025(Part-1)1987(RA 2019)
	Sample Collected On	27.08.2024
	Date of Performance (s)	28.08.2024
	Ref No.	-

**Analysis Result**

Sl. No.	Test Parameter	Unit	Test Method	Result	IS 10500:2012 Amd. 1&2		Remarks
					Acceptable Limit	Permissible Limit	
1	pH at 25 °C		IS 3025 (Part 11) : 2022	7.20	6.5	8.5	
2	Turbidity	NTU	IS 3025 (Part 10) : 2023	1.1	1	5	
3	Total Dissolved Solids (TDS)	mg/l	IS 3025 (Part 16) : 2023	385	500	2000	
4	Total Hardness (as CaCO <sub>3</sub> )	mg/l	IS 3025 (Part 21) : 2009 (RA- 2019)	180.32	200	600	
5	Calcium (as Ca)	mg/l	IS 3025 (Part 40) : 1991 (RA- 2019)	54.06	75	200	
6	Magnesium (as Mg)	mg/l	IS 3025 (Part 46) : 1994 (RA- 2019)	10.81	30	100	
7	Chloride (as Cl)	mg/l	IS 3025 (Part 32) : 1988 (RA- 2019)	90.61	250	1000	
8	Total Alkalinity (as CaCO <sub>3</sub> )	mg/l	IS 3025 (Part 23) : 1986 (RA- 2019)	190.08	200	600	

Authorised Signatory:-

Name: - Sri Brihaspati Yadav

Designation: - Chemist

Disclaimer:-

The report shall not be reproduced except in full, without approval of the laboratory.

*Ravi*

PRINCIPAL

MAHAVIRI SARASWATI VIDYA MANDIR  
Panchmandira, Barhan Gopal, Siwan-841227  
Affiliation No. 330800, School No. 65797

*A*

सचिव

म०स०वि० मंदिर

पंचमंदिरा कचहरी गोपाल, सिवान